



December 6, 2021

### BID BULLETIN NO. 1

Pursuant to section 8.4.3 of the 2016 Revised IRR of RA 9184 which states that “*The Supplemental/Bid Bulletins mentioned in the immediately preceding Subsection as well as all other notices to be made by the BAC to the bidders or prospective bidders shall be posted in the PhilGEPS bulletin board and sent electronically to the e-mail address indicated in the bidders’ registration.*”.

This Addendum is issued to modify or amend the prospective bidders’ concerns in the technical specifications in the published/posted Invitation to Bid (ITB). This amendment shall form an integral part of the Bidding Documents for the contract:

Ref. No.	PROJECT/S	ABC/ Source of Funds (Php)	Work Description
R3-2021-I-01	Construction of Three (3) Storey Building of NHA Tarlac/Nueva Ecija/Aurora District Office with Commercial Space and Perimeter Fence at Brgy. Burot, Tarlac City, Tarlac	36,969,625.81 / Corporate Receipts	Construction of Three (3) Storey Building

CONCERNS	AMENDMENTS/ CLARIFICATIONS
Discrepancy on the provided Concrete Compressive Strength on Plans and Technical Specification, 4000 PSI and 3000 PSI respectively.	The Concrete Compressive Strength is 3000 PSI (21 Mpa @28 days)

For guidance and information of all concerned.

**ROGIE C. PINEDA**

Officer-in-Charge, Pampanga/Bataan/Zambales Office  
Chairperson, Region III Office Bids and Awards Committee